

Ultimate Performance of a Superconducting Quantum Detector



Alexei Semenov

DLR Institute of Planetary Research

Berlin

Andreas Engel, DLR Konstantin II'in, Uni Karlsruhe, Germany Heinz-Wilhelm Hübers, DLR Michael Siegel, Uni Karlsruhe, Germany





Institut für Weltraumsemsorik und Planetenerkundung



OUTLINE



Idea – Mechanism

• HOT-SOPT Mechanism of Single photon Detection in a current carrying superconducting film

Experiment - Verification

• NbN and Nb single-photon detectors. They work, but...

Modified NbN – first confirmation of the mechanism

Applications

• Background limited quantum detector for astronomy

 Quantum detector for X-ray spectroscopy and microanalysis



Microscopically uniform and discrete detection regimes



 $3 \cdot 10^{-24} \text{ W/cm}^2 (\tau_{\text{T}} \approx 10^{-6} \text{ s}, 0.1 \text{ K})$







Current Assisted Hot-Spot Detection Regime



A.Semenov et. al, Physica C 351, 349 (2001), European J. Appl. Phys. (2003)

Detection criteria

 $2\frac{r_m}{w} \ge 1 - \frac{I}{I_C}$



$$r_{m} = \sqrt{\zeta \frac{h\nu}{\Delta} \frac{1}{2 D \tau_{th} d N_{0} \Delta}} \left(\frac{1}{\pi^{4} N_{0} \Delta}\right)^{1/3} \ln\left(1 + \pi^{2} \frac{h\nu}{\Delta} \frac{1}{D \tau_{th} d N_{0} \Delta}\right)^{1/3}$$

The detection mechanism features:

- tunable spectral cutoff

$$r_m \propto \sqrt{h \nu / T_C}$$

- energy resolution





Multiphonon process



Ud-10.80.





Institut für Weltraumsemsorik und Planetenerkundung



Experimental data single & multiphoton regime



Average number of photons per pulse

Göl'tsman et all, APL 2001, MSPU in co-operation with the University of Rochester, USA

Time delay of the resistive state formation has Been recently demonstrated that confirms the current assisted nature of the detection mechanism. Uni. Rochester & MSPU, PRB 2003





Experimental data Beyond the spectral cut-off ?



Thicker films or those with better diffusivity shows no plateau - detection efficiency decreases with the wavelength

NbN - Verevkin et all, APL 2002



Experimental data Beyond the spectral cut-off ?



There is no plateau in the current dependences of the detection efficiency, instead it continuously Drops when current decreases. The slope depends on the photon energy

Verevkin et all, APL 2002



What about another material?

We used NbN films deposited at low N₂ pressure and at a high deposition rate. Nitrogen deficiency resulted in lower transition temperature, smaller critical current and reduced density of electronic states.





Spectral cut-off



The hot-spot model predicts constant efficiency before the cut-off and vanishing efficiency at larger wavelengths. Indeed, there appears the plateau and the clearly seen roll-off wavelength that depends on the bias current





Signal counts vs Bias Current



Current dependences of signal counts show almost "ideal" behaviour. However, the model predicts abrupt drop of the efficiency beyond the roll-off





Energy resolution



The HWFM resolution of 12 eV was found for unoptimized readout.

C







Experimental data Dark counts



$$n = A_R \exp\left[-\frac{\Delta F \,\xi^2 d}{k_B T} \left(1 - \left(\frac{I}{I_C}\right)^2\right)\right]$$

Dark counts appear due to order-parameter fluctuations. Relevant volume has the size comparable to the coherence length.





Edge effect





Nonuniformities as possible reason for current dependence of QE





Morphologe of 3-nm thick NbN film







Applications



- Debugging of transistors in the PC processors –

University of Rochester & MSPU

- Spectroscopy of interstellar dust clouds at wavelengths around 70 mm.

Background limited performance down to 4 K telescope temperature

- X-ray spectroscopy

1 ppm energy resolution

- Solar blind applications where UV photons are detected in the presence of bright visible photon sources.

Tune the cut-off wavelength to ultraviolet

- Another foreseen applications – tracing dynamics of single molecules, Quantum cryptography.



Background limited quantum detector for astronomy

Computed Noise Equivalent Power for the Ti direct quantum detector



Expected energy resolution at 40 μ m – 1/20 that is sufficient for spectroscopy of interstellar dust clouds



X-Ray Photon Counter

Response duration of the Ta X-ray photon counter as function of the photon energy



Pixel 2.5 X 2.5 μ m² Film thickness 70 nm Projected energy resolution - $\approx 10^{-4}$ for 6 keV photons



CONCLUSION

The mechanism of current-assisted hot-spot single photon detection in a current biased superconducting film has been proposed

Practical NbN Superconducting Quantum Detectors have been demonstrated, although the mechanism is not yet fully proved.

Variation of the material parameters allowed us to observe key features of the envisioned detection mechanism.

The technology seems to be feasible for further applications. To prove that study of SQD based on another materials is necessary.

Special thanks to: Gregory Gol'tsman Alexander Korneev Oleg Okunev

